

**ALL INDIA
BHARAT SANCHAR NIGAM LIMITED
EXECUTIVES' ASSOCIATION**



**Central Headquarters
New Delhi-110001**

**President
Subhasis Mitra**

Mob:9432001010

E-mail:presidentaibsnlea@gmail.com

**General Secretary
S.Sivakumar**

Mob:9773760445

E-mail:gsaibsnlea@gmail.com

**Financial Secretary
Ram Nath**

Mob:9868231711

E-mail:fsaibsnlea@gmail.com

No. AIBSNLEA/CHQ/CMD/2020

Dated: 29.01.2020

To,

**Shri. P.K.Purwar,
CMD, BSNL
New Delhi -110001.**

**Subject Non standardized installation at CLS, New Telephone Exchange Port Blair-
Reg.**

Respected Sir,

We would like to bring to your kind notice about the Non standardized installation at CLS, New Telephone Exchange Port Blair in Andaman Nicobar Telecom Circle. In this regard, kindly find enclosed herewith the letter received from the Circle Secretary, AIBSNLEA, . Andaman Nicobar Telecom Circle which is self explanatory.

Sir, CANI Project equipments were installed by M/s NEC in New Telephone Exchange Port Blair and the expected DC load of the equipments is 450 Amps. For the mentioned load, the capacity of Battery Banks to be installed should be at least 5000 AH since this Cable Landing Station will be full responsible for the entire Bandwidth of Andaman & Nicobar Islands including other TSPs, Defence and A & N Administration.

But, it is observed that the qualified technical officers have installed 02 Battery Sets of 400 AH and connected with armored cables. The capacity of Battery and installation cables are entirely not standardized and not expected from an engineer. In case of Power cut the Battery and Cable due to the load may even burn and lead to shut down of transmission equipments of CLS, further a huge loss to all TSPs including BSNL .

It will not be good for BSNL if such an activity occurs and BSNL can't justify the outage of equipments too.

Hence, it is requested to kindly intervene in the matter and arrange to issue necessary instructions to the Officer concern to change the existing Battery Banks with recommended Battery Banks and retain glory of BSNL.

With kind regards

Yours Sincerely,
-sd-

**(S.Sivakumar)
General Secretary**

Copy for kind information and necessary action to:

1. Shri Sheetla Prasad, Director (CM), BSNL Board, New Delhi-110001
2. Shri A.M. Gupta, GM (SR) BSNL CO, New Delhi -110001